



Notes:

- 1) Primary treatment may not be required for activated sludge or SBR processes.
- 2) Secondary clarifiers are part of the biological treatment process for the activated sludge and RBC processes.
- 3) Disinfection is not required if effluent disposal is into sub-surface leaching beds outside of a Zone II.
- 4) Effluent filtration is already provided in the Amphidrome and Zenon processes, and may not be needed for other processes depending on the effluent discharge method (outside of a Zone II).
- 5) Facilities with effluent disposal facilities within Zone Iis will have stricter requirements and may require filtration, disinfection, and possibly other treatment processes.



Date: 12/2008 Project No. 61204

**TOWN OF EASTHAM, MASSACHUSETTS**

**COMMUNITY/MUNICIPAL TREATMENT  
SYSTEM COMPONENTS**

**FIGURE 8-1**